



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

MONTHLY OPERATION REPORT - CLASS D WATER TREATMENT PLANT

Issued under authority of 1976 PA 399 and the Administrative Rules, as amended. Administrative Rule R 325.11512 says in part, "A supplier of water where treatment is employed shall prepare an operation report on a form provided by the department for each month of operation." Failure to submit this form is a violation of the Act and may subject the water supply to enforcement penalties.

Water Supply Information

City of Morenci		004490
Supply Name		WSSN
Paul D. Seegert (Temporary-OIC)	D-3, S-3	Jan
Operator In Charge (OIC)	System Classification	Month
F-1, S-2	Lenawee	2020
Certification Level of OIC	County	Year

Distribution Chlorine Residual Monitoring

(Sampling Conducted per DBPR Monitoring Plan)

Number of chlorine residual measurements taken during the month:	39 - Various Distribution Sites
Number of chlorine residual measurements that exceeded 4 mg/L:	0
Monthly average "free" chlorine residual:	0.66

Comments

Plant tap (which is N/A) residuals are take at the first hydrant downstream from the iron removal water treatment plant (approximately 300' downstream of the IRP filters).

Certification

Paul D. Seegert (Temporary OIC)	
Name and Title of Authorized Agent	
<i>Paul D. Seegert</i>	2/9/2020
Signature	Date Submitted

Send Completed Report To:

Department of Environmental Quality (DEQ)  
 Office of Drinking Water and  
 Municipal Assistance  
 301 East Louis Glick Highway  
 Jackson, Michigan, 49201  
 Or submit via email to  
[EGLE-DWEH-Jackson@michigan.gov](mailto:EGLE-DWEH-Jackson@michigan.gov)

Staff and Contact Information

Taryn Simon, EQA	517-257-7465
Caitlin Bates, District Engineer;	517-262-6795
Pat Brennan, District Sup'r;	517-581-2769
Fax;	517-780-7855
PEAS Hotline;	1-800-292-4706

City of Morenci

4490

Jan-20

Name of Supply

WSSN

Day of the month	Raw Pumpage in Million of Gallons per Day		Raw Pumpage Daily Total MGD	Raw Water To Iron Removal Plant MG	Raw Water To Iron Removal Plant Lbs	Comments
	Well 1	Well 2				
1	0.243		0.243	0.243	2.027	
2	0.160		0.160	0.160	1.334	
3	0.237		0.237	0.237	1.977	
4	0.275		0.275	0.275	2.294	
5	0.223		0.223	0.223	1.860	
6	0.182		0.182	0.182	1.518	
7	0.205	0.014	0.219	0.219	1.822	Bacteriological sample - Well meter is not operational (Estimated.)
8	0.215		0.215	0.215	1.793	
9	0.179		0.179	0.179	1.493	
10	0.133		0.133	0.133	1.109	
11	0.197		0.197	0.197	1.643	
12	0.218		0.218	0.218	1.818	
13	0.225		0.225	0.225	1.877	
14	0.224		0.224	0.224	1.868	
15	0.172		0.172	0.172	1.434	
16	0.223		0.223	0.223	1.860	
17	0.216		0.216	0.216	1.801	
18	0.204		0.204	0.204	1.701	
19	0.213		0.213	0.213	1.776	
20	0.168		0.168	0.168	1.401	
21	0.190	0.014	0.204	0.204	1.697	Bacteriological sample - Well meter is not operational (Estimated.)
22	0.213		0.213	0.213	1.776	
23	0.235		0.235	0.235	1.960	
24	0.194		0.194	0.194	1.618	
25	0.217		0.217	0.217	1.810	
26	0.211		0.211	0.211	1.760	
27	0.189		0.189	0.189	1.576	
28	0.181		0.181	0.181	1.510	
29	0.185		0.185	0.185	1.543	
30	0.183		0.183	0.183	1.526	
31	0.255		0.255	0.255	2.127	
Total	6.365	0.027	6.392	6.392	53.309	
Avg	0.205	0.014	0.219	0.219	1.825	
Max	0.275	0.014	0.289	0.289	2.406	
Min	0.133	0.014	0.147	0.147	1.222	

Pumpage

Day of the month	Water in Millions of Gallons				Head Loss Thru Filter ft/psi	Oxidant/Chlorine		Plant Tap Chlorine Residual		IRP Filter Chlorine Residual		Plant Tap Analysis	
	Raw Water To Plant	Filter Backwash To WWTP	Total Water To System	Total Million Pounds		Cl <sub>2</sub> Applied Pounds	Cl <sub>2</sub> Applied mg/L	Free	Total	Free	Total	Iron as Fe mg/L	Manganese as Mn mg/L
1	0.243		0.243	2.027		8.0	3.95	1.01	1.19	0.30	0.51		
2	0.160		0.160	1.334		5.0	3.75	1.08	1.26	0.03	0.44		
3	0.237	0.040	0.197	1.977		6.0	3.04	0.73	0.78	0.05	0.16		
4	0.275		0.275	2.294		7.0	3.05	1.09	1.16	0.10	0.29		
5	0.223		0.223	1.860		7.0	3.76	0.22	0.34	0.10	0.26		
6	0.182		0.182	1.518		5.0	3.29	0.55	0.71	0.37	0.40		
7	0.219		0.219	1.822		6.0	3.29	0.44	0.53	0.20	0.21		
8	0.215		0.215	1.793		6.0	3.35			0.05	0.33		
9	0.179		0.179	1.493		6.0	4.02	0.83	0.94	0.33	0.40		
10	0.133	0.040	0.093	1.109		3.0	2.70	0.49	0.60	0.14	0.26		
11	0.197		0.197	1.643		6.0	3.65	0.32	0.41	0.26	0.32		
12	0.218		0.218	1.818		6.0	3.30			0.13	0.38		
13	0.225		0.225	1.877		5.0	2.66	0.48	0.62	0.19	0.22		
14	0.224		0.224	1.868		5.0	2.68	0.37	0.46	0.20	0.22		
15	0.172		0.172	1.434		5.0	3.49	0.63	0.75	0.34	0.35		
16	0.223		0.223	1.860		4.0	2.15			0.29	0.30		
17	0.216	0.040	0.176	1.801		4.0	2.22	0.31	0.39	0.16	0.24		
18	0.204		0.204	1.701		6.0	3.53			0.29	0.40		
19	0.213		0.213	1.776		5.0	2.81			0.08	0.59		
20	0.168		0.168	1.401		4.0	2.85			0.34	0.35		
21	0.204		0.204	1.697		6.0	3.54			0.11	0.25		
22	0.213		0.213	1.776		5.0	2.81			0.03	0.33		
23	0.235		0.235	1.960		7.0	3.57			0.01	0.23		
24	0.194	0.040	0.154	1.618		4.0	2.47	1.35	1.39	0.07	0.09		
25	0.217		0.217	1.810		6.0	3.32			0.02	0.15		
26	0.211		0.211	1.760		6.0	3.41			0.02	0.24		
27	0.189		0.189	1.576		4.0	2.54			0.13	0.22		
28	0.181		0.181	1.510		5.0	3.31			0.25	0.27		
29	0.185		0.185	1.543		4.0	2.59			0.21	0.30		
30	0.183		0.183	1.526		5.0	3.28			0.22	0.25		
31	0.255	0.040	0.215	2.127		7.0	3.29			0.58	0.66		
Total	6.392	0.200	6.192	53.309		168.0	97.68	9.90	11.53	5.6	9.6		
Avg	0.206	0.040	0.200	1.720		5.4	3.15	0.66	0.77	0.18	0.31		
Max	0.275	0.040	0.275	2.294		8.0	4.02	1.35	1.39	0.58	0.66		
Min	0.133	0.040	0.093	1.109		3.0	2.15	0.22	0.34	0.01	0.09		

Name of Supply

WSSN

Day of Month	Conductivity		Temperature		Total - Hardness mg/L		Total - Alkalinity mg/L		Chloride mg/l		Calcium mg/l		Iron mg/l		Manganese mg/L		Sulfate mg/l		pH Analysis		Phosphate mg/l	
	Raw Sample Tap	Plant Tap	Raw Temp°C	Tap Temp°C	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap	Raw Sample Tap	Plant Tap
1																						
2																						
3																						
4																						
5																						
6																						
7		680		12.2		266		270		6.0		72.0					10.0			7.52		
8																						
9																						
10																						
11																						
12																						
13																						
14																						
15																						
16																						
17																						
18																						
19																						
20																						
21																						
22																						
23																						
24		695		7.8 *		270		274		6.5		143.0					13.0			7.69		
25																						
26																						
27																						
28																						
29																						
30																						
31																						
Total:																						
Average:		687.5		12.2		268.0		272.0		6.3		107.5					11.5			7.61		
Maximum:		695.0		12.2		270.0		274.0		6.5		143.0					13.0			7.69		
Minimum:		680.0		12.2		266.0		270.0		6.0		72.0					10.0			7.52		

Comments: \* Temperature 1/24/2020 - sample delivery was outside for 30 minutes.

Day of the month	Treated Water		Oxidant / Chlorine		Chlorine Residual mg/L						Comments	
	Metered		Avail 99.8% Cl <sub>2</sub> Gas in lbs	Cl <sub>2</sub> Applied mg/L	Plant Tap (Hydrant)		Distribution System		Distribution System Location	Applied IRP Filters		
	Million Gallons	Million lbs			Free	Total	Free	Total		Free		Total
1	0.243	2.027	8.0	3.95	1.01	1.19				0.30	0.51	
2	0.160	1.334	5.0	3.75	1.08	1.26				0.03	0.44	
3	0.237	1.977	6.0	3.04	0.73	0.78				0.05	0.16	
4	0.275	2.294	7.0	3.05	1.09	1.16				0.10	0.29	
5	0.223	1.860	7.0	3.76	0.22	0.34				0.10	0.26	
6	0.182	1.518	5.0	3.29	0.55	0.71				0.37	0.40	
7	0.219	1.822	6.0	3.29	0.44	0.53				0.20	0.21	
8	0.215	1.793	6.0	3.35						0.05	0.33	
9	0.179	1.493	6.0	4.02	0.83	0.94				0.33	0.40	
10	0.133	1.109	3.0	2.70	0.49	0.60				0.14	0.26	
11	0.197	1.643	6.0	3.65	0.32	0.41				0.26	0.32	
12	0.218	1.818	6.0	3.30	0.00	0.00	0.49	0.60	BP Gas Station	0.13	0.38	
13	0.225	1.877	5.0	2.66	0.48	0.62				0.19	0.22	
14	0.224	1.868	5.0	2.68	0.37	0.46				0.20	0.22	
15	0.172	1.434	5.0	3.49	0.63	0.75	0.66	0.67	City Hall	0.34	0.31	
16	0.223	1.860	4.0	2.15			0.85	0.90	City Hall	0.29	0.30	
17	0.216	1.801	4.0	2.22	0.31	0.39	0.44	0.52	City Hall	0.16	0.24	
18	0.204	1.701	6.0	3.53			0.29	0.58	DPW Barn	0.29	0.40	
19	0.213	1.776	5.0	2.81			0.30	0.37	DPW Barn	0.08	0.59	
20	0.168	1.401	4.0	2.85			0.42	0.51	DPW Barn	0.34	0.35	
21	0.204	1.697	6.0	3.54			0.39	0.43	DPW Barn	0.11	0.25	
22	0.213	1.776	5.0	2.81			0.41	0.53	City Hall	0.03	0.33	
23	0.235	1.960	7.0	3.57			0.38	0.51	City Hall	0.01	0.23	
24	0.194	1.618	4.0	2.47	1.35	1.39				0.07	0.09	
25	0.217	1.810	6.0	3.32			0.38	0.44	DPW Barn	0.02	0.15	
26	0.211	1.760	6.0	3.41			0.58	0.67	DPW Barn	0.02	0.24	
27	0.189	1.576	4.0	2.54			0.55	0.63	DPW Barn	0.13	0.22	
28	0.181	1.510	5.0	3.31			0.60	0.65	DPW Barn	0.25	0.27	
29	0.185	1.543	4.0	2.59			0.53	0.62	DPW Barn	0.21	0.30	
30	0.183	1.526	5.0	3.28			0.52	0.60	DPW Barn	0.22	0.25	
31	0.255	2.127	7.0	3.29			0.49	0.59	DPW Barn	0.58	0.66	
Total	6.392	53.309	168.0			11.5	8.3	9.8		5.6	9.6	
Avg	0.219	1.720	5.4	3.15	0.66	0.77	0.49	0.58		0.18	0.31	
Max	0.289	2.294	8.0	4.02	1.35	1.39	0.85	0.90		0.58	0.66	
Min	0.147	1.109	3.0	2.15	0.22	0.34	0.29	0.37		0.01	0.09	

City of Morenci

004490

Jan 2020

Name of Supply

WSSN

Month

Year

2	Routine samples required	0	Repeat samples taken	Cl <sub>2</sub> residuals from routine & repeat		
4	Routine samples taken	0	Repeat samples total coliform positive			
0	Routine samples positive	P/A	Analytical Method			
				Average	0.80	0.94
				Maximum	1.17	1.32
				Minumum	0.31	0.40

Distribution System - Routine Samples			Chlorine Residual (mg/L)	
Count	Sample Location	Date Collected	Free	Total
1	607 Maple Street (Sample Tap Maintenance at 597 W Chestnut)	01/07/20	0.31	0.40
2	118 Orchard Street	01/07/20	0.63	0.77
3	485 West Main - Well #1 - Raw	01/07/20	N/A	N/A
4	485 West Main - Well #2 - Raw	01/07/20	N/A	N/A
5	597 West Chestnut	01/21/20	1.17	1.32
6	118 Orchard Street	01/21/20	1.10	1.27
7	485 West Main - Well #1 - Raw	01/21/20	N/A	N/A
8	485 West Main - Well #2 - Raw	01/21/20	N/A	N/A
9				
10				
11				
12				
13				
14				
15				
16				
17				
19				

Distribution System - Repeat Samples-Contact District if > one Positive			Chlorine Residual (mg/L)	
Count	Sample Location	Date Collected	Free	Total
1				
2				
3				
4				
5				
6				
7				
8				
9				

Other: Triggered Source Water Samples, entry point (plant tap) ...			Chlorine Residual (mg/L)	
Count	Sample Location	Date Collected	Free	Total
1				
2				
3				
4				
5				
6				
7				
8				
9				

DRINKING WATER ANALYSIS			DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)		
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350					
COMPLETE FOR ALL SAMPLES (Please Print)					
WSSN or Pool ID# 004490	Chlorinated? <input checked="" type="checkbox"/> No	Cl- Residual F-0.63 mg/L 7-0.77	Received in Lab Date: 7/14/20 Time: 11:27	Incubator Time In: 11:30	Sample ID# 7169
Sample Collector Name PAUL D. SEEGERT	Date Collected 1-7-2020	Time Collected 10:20 AM	Analysis	Result	Comment
System/ Owner Name City Of Morenci	Collection Site (street address) 118 ORCHARD STREET		Analyt Negotio N. Kiefer		
City/Twp. Morenci MI	State MI	County Lenawee	Zip 49256	A TRUE COPY VILLAGE OF BLISSFIELD WTP	
Sampling Point (kitchen, bath, etc.) BATH FAUCET	Phone Number 517.458.6828		E. coli Enumeration		
REPORT RESULTS TO: (please print)					
Name City Of Morenci - Michael Sessions					
Address 118 ORCHARD STREET					
City Morenci	State MI	Zip 49256	CHEMICAL		
Signature Paul D Synt	PD	CH	PS	FU	TX
			FK		

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS			DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)		
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350					
COMPLETE FOR ALL SAMPLES (Please Print)					
WSSN or Pool ID# 004490	Chlorinated? <input checked="" type="checkbox"/> No	Cl- Residual F-0.30 mg/L 7-0.10	Received in Lab Date: 7/14/20 Time: 11:27	Incubator Time In: 11:30	Sample ID# 7168
Sample Collector Name PAUL D. SEEGERT	Date Collected 1-7-2020	Time Collected 10:45 A	Analysis	Result	Comment
System/ Owner Name City Of Morenci	Collection Site (street address) 607 MAPLE DRIVE		Analyt Negotio N. Kiefer		
City/Twp. Morenci MI	State MI	County Lenawee	Zip 49256	A TRUE COPY VILLAGE OF BLISSFIELD WTP	
Sampling Point (kitchen, bath, etc.) BATHROOM FAUCET	Phone Number 517.458.6828		E. coli Enumeration		
REPORT RESULTS TO: (please print)					
Name City Of Morenci - Michael Sessions					
Address 118 ORCHARD STREET					
City Morenci	State MI	Zip 49256	CHEMICAL		
Signature Paul D Synt	PD	CH	PS	FU	TX
			FK		

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 004490	Chlorinated? <input checked="" type="radio"/> No	Cl-Residual 1.10-free mg/L 1.27-tot		Received in Lab Date: 1/21/20	Incubator Time In: 11:40	Out: 11:45	Sample ID# 7220
Sample Collector Name PAUL SEEGERT	Date Collected 1-21-20	Time Collected 10:15 a.m.		Comment			
System/ Owner Name CITY OF MORENCI	Collection Site (street address) 112 ORCHARD ST.			Analyst N. Kujala			
City/Twp. MORENCI	State MI	County LENAWEE	Zip 49256	Result			
Sampling Point (kitchen, bath, etc.) CITY HALL-BATHROOM	Phone Number 517.458.6828			BACTERIOLOGICAL			
REPORT RESULTS TO: (please print)				Coliform			
Name CITY OF MORENCI				MF			
Address 112 ORCHARD STREET				HPC			
City MORENCI		State MI	Zip 49256	E. coli Enumeration			
Signature Paul J. Sjut		PD <input type="checkbox"/> OH <input type="checkbox"/> MI <input checked="" type="checkbox"/> IN <input type="checkbox"/> TX <input type="checkbox"/> FL <input type="checkbox"/>		CHEMICAL			
				Chlorine			
				Fluoride			
				Nitrate			
				A TRUE COPY			
				VILLAGE OF BLISSFIELD			
				WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 004490	Chlorinated? <input checked="" type="radio"/> No	Cl-Residual F-1.17 mg/L T-1.82		Received in Lab Date: 1/21/20	Incubator Time In: 11:40	Out: 11:45	Sample ID# 7221
Sample Collector Name PAUL SEEGERT	Date Collected 1-21-20	Time Collected		Comment			
System/ Owner Name CITY OF MORENCI	Collection Site (street address) 597 WEST CHESTNUT			Analyst N. Kujala			
City/Twp. MORENCI	State MI	County LENAWEE	Zip 49256	Result			
Sampling Point (kitchen, bath, etc.) BATHROOM SINK	Phone Number 517.458.6828			BACTERIOLOGICAL			
REPORT RESULTS TO: (please print)				Coliform			
Name CITY OF MORENCI				MF			
Address 112 ORCHARD STREET				HPC			
City MORENCI		State MI	Zip 49256	E. coli Enumeration			
Signature Paul J. Sjut		PD <input type="checkbox"/> OH <input type="checkbox"/> MI <input checked="" type="checkbox"/> IN <input type="checkbox"/> TX <input type="checkbox"/> FL <input type="checkbox"/>		CHEMICAL			
				Chlorine			
				Fluoride			
				Nitrate			
				A TRUE COPY			
				VILLAGE OF BLISSFIELD			
				WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.



DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 004490	Chlorinated? Yes <input checked="" type="checkbox"/>	Cl- Residual mg/L		Sample ID# 7167		Comment	
Sampler Collector Name PAUL SEEGERLT	Date Collected 1-7-2020	Time Collected 1000 AM		Incubator Time In: 1:30 Out: 1:12		Analyst N. Kurb	
System/ Owner Name CITY OF MORENCI	Collection Site (street address) 485 W. MAIN- WELL #2			Sample ID#		Comment	
City/Town MORENCI	State MI	County LENAWEE	Zip 49256	Incubator Time In: 1:30 Out: 1:12		Analyst N. Kurb	
Sampling Point (kitchen, bath, etc.) WELL #2 SAMPLE TAP	Phone Number 517.458.6828			Sample ID#		Comment	
REPORT RESULTS TO: (please print)							
Name CITY OF MORENCI - MICHAEL SESSIONS							
Address 118 ORCHARD STREET							
City MORENCI	State MI	Zip 49256		Sample ID#		Comment	
Signature Paul Seegerlt	PD <input checked="" type="checkbox"/>	CH <input type="checkbox"/>	PS <input type="checkbox"/>	PU <input type="checkbox"/>	TX <input type="checkbox"/>	FX <input type="checkbox"/>	
BACTERIOLOGICAL				Result			
Coliform				Negative			
MF							
HPC							
E. coli Enumeration							
CHEMICAL				A TRUE COPY VILLAGE OF BLISSFIELD WTP			
Chlorine							
Fluoride							
Nitrate							

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 004490	Chlorinated? Yes <input checked="" type="checkbox"/>	Cl- Residual mg/L		Sample ID# 7166		Comment	
Sampler Collector Name PAUL SEEGERLT	Date Collected 1-7-2020	Time Collected 09:40 A		Incubator Time In: 1:30 Out: 1:12		Analyst N. Kurb	
System/ Owner Name CITY OF MORENCI	Collection Site (street address) 485 W. MAIN- WELL #1			Sample ID#		Comment	
City/Town MORENCI	State MI	County LENAWEE	Zip 49256	Incubator Time In: 1:30 Out: 1:12		Analyst N. Kurb	
Sampling Point (kitchen, bath, etc.) WELL #1 SAMPLE TAP	Phone Number 517.458.6828			Sample ID#		Comment	
REPORT RESULTS TO: (please print)							
Name CITY OF MORENCI - MICHAEL SESSIONS							
Address 118 ORCHARD STREET							
City MORENCI	State MI	Zip 49256		Sample ID#		Comment	
Signature Paul Seegerlt	PD <input checked="" type="checkbox"/>	CH <input type="checkbox"/>	PS <input type="checkbox"/>	PU <input type="checkbox"/>	TX <input type="checkbox"/>	FX <input type="checkbox"/>	
BACTERIOLOGICAL				Result			
Coliform				Negative			
MF							
HPC							
E. coli Enumeration							
CHEMICAL				A TRUE COPY VILLAGE OF BLISSFIELD WTP			
Chlorine							
Fluoride							
Nitrate							

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WBSN or Pool ID# 004490	Chlorinated? Yes <input checked="" type="radio"/> No <input type="radio"/>	Cl- Residual mg/L		Sample ID# 7223 Comment			
Sample Collector Name PAUL SEEGER	Date Collected 1-21-20	Time Collected 9:45 AM					
System/ Owner Name CITY OF MORENCI		Collection Site (street address) 485 WEST MAIN		Analyt Naghib N. Khatir			
City/Twp. MORENCI	State MI	County LELAND	Zip 49256				
Sampling Point (kitchen, bath, etc.) IRP-Well #2		Phone Number 517.458.6828		Result Negative			
REPORT RESULTS TO: (please print)							
Name CITY OF MORENCI				Received in Lab Date: 1/21/20 In: 11:30 Incubator Time Out: 11:45			
Address 118 ORCHARD STREET							
City MORENCI		State MI	Zip 49256	Analysis Coliform MF HPC E. coli Enumeration CHEMICAL			
Signature Paul Seeger		<input type="checkbox"/> PD <input checked="" type="checkbox"/> CH <input checked="" type="checkbox"/> RP <input type="checkbox"/> PU <input type="checkbox"/> TX <input type="checkbox"/> FX					
				A TRUE COPY VILLAGE OF BLISSFIELD WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WBSN or Pool ID# 004490	Chlorinated? Yes <input checked="" type="radio"/> No <input type="radio"/>	Cl- Residual mg/L		Sample ID# 7222 Comment			
Sample Collector Name PAUL SEEGER	Date Collected 1-21-20	Time Collected 9:30 AM					
System/ Owner Name CITY OF MORENCI		Collection Site (street address) 485 WEST MAIN		Analyt Naghib N. Khatir			
City/Twp. MORENCI	State MI	County LELAND	Zip 49256				
Sampling Point (kitchen, bath, etc.) IRP-Well #1		Phone Number 517.458.6828		Result Negative			
REPORT RESULTS TO: (please print)							
Name CITY OF MORENCI				Received in Lab Date: 1/21/20 In: 11:30 Incubator Time Out: 11:40			
Address 118 ORCHARD STREET							
City MORENCI		State MI	Zip 49256	Analysis Coliform MF HPC E. coli Enumeration CHEMICAL			
Signature Paul Seeger		<input type="checkbox"/> PD <input checked="" type="checkbox"/> CH <input checked="" type="checkbox"/> RP <input type="checkbox"/> PU <input type="checkbox"/> TX <input type="checkbox"/> FX					
				A TRUE COPY VILLAGE OF BLISSFIELD WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.