

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 04490	Chlorinated? Yes <input checked="" type="radio"/> No	Cl- Residual mg/L		Sample ID# 8609	Comment		
Sample Collector Name Kipp Scott	Date Collected 3-10-2021	Time Collected 9:30 AM		Incubator Time In: 1305 Out: 1855	Analyst J. White		
System/ Owner Name City of Morenci	Collection Site (street address) 485 W. Main						
City/Twp. Morenci	State MI.	County LeNawEE	Zip 49256	Received in Lab Date: 3/10/21 Time: 1300	Result		
Sampling Point (kitchen, bath, etc.) Well # 1	Phone Number 517 438 0864			BACTERIOLOGICAL			
REPORT RESULTS TO: (please print)				Coliform <input checked="" type="radio"/> Neg.			
Name City of Morenci	Address 118 Orchard St.			MF			
City Morenci	State MI.	Zip 49256		HPC			
Signature	PD <input checked="" type="radio"/> PS PU TX FX			E. coli Enumeration			
				CHEMICAL			
				Chlorine			
				Fluoride			
				Nitrate			
				A TRUE COPY VILLAGE OF BLISSFIELD WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS				DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)			
Village of Blissfield W.T.P. Laboratory MDEQ ID#0750 1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350							
COMPLETE FOR ALL SAMPLES (Please Print)							
WSSN or Pool ID# 04490	Chlorinated? Yes <input checked="" type="radio"/> No	Cl- Residual mg/L		Sample ID# 8608	Comment		
Sample Collector Name Kipp Scott	Date Collected 3-10-2021	Time Collected 9:45 AM		Incubator Time In: 1305 Out: 1855	Analyst J. White		
System/ Owner Name City of Morenci	Collection Site (street address) 485 W. Main						
City/Twp. Morenci	State MI.	County LeNawEE	Zip 49256	Received in Lab Date: 3/10/21 Time: 1300	Result		
Sampling Point (kitchen, bath, etc.) Well # 2	Phone Number 517 438 0864			BACTERIOLOGICAL			
REPORT RESULTS TO: (please print)				Coliform <input checked="" type="radio"/> Neg.			
Name City of Morenci	Address 118 Orchard St.			MF			
City Morenci	State MI.	Zip 49256		HPC			
Signature	PD <input checked="" type="radio"/> PS PU TX FX			E. coli Enumeration			
				CHEMICAL			
				Chlorine			
				Fluoride			
				Nitrate			
				A TRUE COPY VILLAGE OF BLISSFIELD WTP			

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS

Village of Blissfield W.T.P. Laboratory MDEQ ID#0750
1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350

COMPLETE FOR ALL SAMPLES (Please Print)

WSSN or Pool ID# 04490	Chlorinated? <input checked="" type="radio"/> Yes <input type="radio"/> No	Cl- Residual mg/L 0.82/1.03
Sample Collector Name KIPP Scott	Date Collected 3-10-2021	Time Collected 10:45 AM
System/ Owner Name City of Morenci	Collection Site (street address) 118 ORCHARD ST.	
City/Twp. Morenci	State MI.	County LeAnnwer
		Zip 49256
Sampling Point (kitchen, bath, etc.) Bath	Phone Number 517 438 0886	

REPORT RESULTS TO: (please print)

Name City of Morenci	Address 118 Orchard St.	
City Morenci	State MI.	Zip 49256
Signature	PD <input checked="" type="radio"/> CH <input type="radio"/> PS <input type="radio"/> PU <input type="radio"/> TX <input type="radio"/> FX	

DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)

Received in Lab Date: 3/10/21 Time: 12:59	Incubator Time In: 13:02 Out: 12:55	Sample ID# 8606	Comment No coliform or E. coli detected
Analysis Result		Analyst J. White	
BACTERIOLOGICAL			
Coliform	Neg.		
MF			
HPC			
E. coli Enumeration			
CHEMICAL			
Chlorine		A TRUE COPY	
Fluoride		VILLAGE OF BLISSFIELD	
Nitrate		WTP	

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.

DRINKING WATER ANALYSIS

Village of Blissfield W.T.P. Laboratory MDEQ ID#0750
1330 Beamer Rd. Blissfield, MI. 49228 (517) 486-3350

COMPLETE FOR ALL SAMPLES (Please Print)

WSSN or Pool ID# 04490	Chlorinated? <input checked="" type="radio"/> Yes <input type="radio"/> No	Cl- Residual mg/L 1.25/1.38
Sample Collector Name KIPP Scott	Date Collected 3-10-2021	Time Collected 11:00 AM
System/ Owner Name City of Morenci	Collection Site (street address) 597 W. Chestnut	
City/Twp. Morenci	State MI.	County LeAnnwer
		Zip 49256
Sampling Point (kitchen, bath, etc.) Bath	Phone Number 517 438 0886	

REPORT RESULTS TO: (please print)

Name City of Morenci	Address 118 Orchard St.	
City Morenci	State MI.	Zip 49256
Signature	PD <input type="radio"/> CH <input checked="" type="radio"/> PS <input type="radio"/> PU <input type="radio"/> TX <input type="radio"/> FX	

DO NOT WRITE IN SHADED AREA (LABORATORY USE ONLY)

Received in Lab Date: 3/10/21 Time: 12:59	Incubator Time In: 13:02 Out: 12:55	Sample ID# 8607	Comment No coliform or E. coli detected
Analysis Result		Analyst J. White	
BACTERIOLOGICAL			
Coliform	Neg.		
MF			
HPC			
E. coli Enumeration			
CHEMICAL			
Chlorine		A TRUE COPY	
Fluoride		VILLAGE OF BLISSFIELD	
Nitrate		WTP	

The analyses performed by the Blissfield Drinking Water Laboratory were conducted using methods approved by the U.S.E.P.A. and other regulatory agencies as appropriate.